

CONDITIONS TO INSTALL SERVICE UNDER ROADS

1. General

- a) Only contractors approved by the WDC Roading Engineer will be permitted to carry out the work.
- b) A copy of these conditions along with the **RON** must be held on the site by the contractor at all times whilst work is in progress.
- c) The work shall not result in any cost being met by the Waimate District Council, and the applicant accepts full responsibility for any consequences of the work.
- d) The Waimate District Council accepts no responsibility for damage to the service arising from its own or any action by other parties.
- e) It shall be the applicants' responsibility to contact all owners of other services to ascertain the position of and their requirements for the protection of such services
- f) The service shall be installed in accordance with the manufactures specifications.
- g) While the work is in progress, provision shall be made for the control and dispersion of storm water. At the completion of the works, all channels and drains are to be restored to the satisfaction of the engineer.
- h) Temporary Traffic Management shall meet the requirements of the Local Roads Supplement to the Transit New Zealand Code of Practice for Temporary Traffic Management.
- i) The surface of a sealed surface shall be saw cut prior to excavation in accordance with Clause 4.5 of SNZ HB 2002
- j) The service shall be marked with a permanent marker post next to the fence line on both sides of the road directly above the service, or offset if necessary. A notice showing the service type, its depth and offset distance (if required) is to be attached to the post

2. Backfill Requirements

- a) The excavation shall be backfilled to 200mm below the surface with GAP 65 or other approved backfill material compacted in accordance with TNZ F/1 specification.
- b) The top 200mm of road pavement shall be backfilled with TNZ M/4 AP40 basecourse, compacted to TNZ B2 specification.

3. Surfacing Requirements.

- a) A sealed road surface must be reinstated with a two coat 4/6 chip seal (unless specified otherwise) within 7 days of backfilling. The surface texture should match the surrounding surface.
- b) On unsealed roads AP 20 metal shall be applied over the area of the carriageway disturbed during the work to a depth of 30mm.
- c) Grassed areas disturbed by the contractors operations shall be reinstated to their pre works condition

4. Maintenance

- a) The applicant will be held responsible for any maintenance work required as a result of the Works for a period of twelve months after application of the final surfacing material.
- b) The Grantee is to be responsible for the control of plant pests, in the areas disturbed by the works, for a period of 2 years.

5 .Special Conditions

- a) The cover over the service shall be _____ mm